

DATE:	LOCATION:	
PERSON(S) CONDUCTING SURVEY:		

GENERAL CONDITION			
CONDITION	YES	NO	RECOMMENDATION/ ADDITIONAL INFO
Confirm that bleachers are stable.			
Ensure adequate bearing on the floor or ground for uniform load support.			
Look for signs of attempted arson (wood bleachers) or other vandalism that may impact the safety of the bleachers.			

FASTENERS & COMPONENTS			
CONDITION	YES	NO	RECOMMENDATION/ ADDITIONAL INFO
Check that all nuts, bolts, and fasteners are present, tight, and corrosion resistant.			
Inspect for broken, damaged, deteriorated, or missing components.			
Verify welds are intact with no cracks.			

BLEACHER INSPECTIONS

GUARDRAILS & SAFETY BARRIERS

CONDITION	YES	NO	RECOMMENDATION/ ADDITIONAL INFO
Guardrails must be present on open sides, backs, and ends where seating is 30 inches or more above the ground.			
Ensure guardrails are at least 42 inches high and openings do not allow a 4-inch sphere to pass through.			
Confirm that guardrails and handrails are secured, stable, and not missing any hardware.			

SEATING & BOARDS

CONDITION	YES	NO	RECOMMENDATION/ ADDITIONAL INFO
All seat and footboards should be securely fastened and free of splinters or cracks.			
Check for gaps between sections and adjust so that a 4-inch sphere cannot pass through			

BLEACHER INSPECTIONS

SURFACE & STRUCTURAL INTEGRITY

CONDITION	YES	NO	RECOMMENDATION/ ADDITIONAL INFO
Look for signs of corrosion, rot, or rust on supports and boards.			
Remove visible rust and touch up with matching paint.			
Lubricate moving parts like footboard support channels with high-grade bearing lubricant			

SAFETY FEATURES

CONDITION	YES	NO	RECOMMENDATION/ ADDITIONAL INFO
Ensure that slide stops and locking mechanisms are functional.			
Confirm signage prohibiting climbing on retracted bleachers is posted.			
Verify electric or telescoping bleachers are operated by staff only			

COMPLIANCE & DOCUMENTATION

CONDITION	YES	NO	RECOMMENDATION/ ADDITIONAL INFO
Quarterly inspections by staff for all bleachers are being conducted.			
Biennial inspections by a professional engineer or certified individual for bleachers five tiers and over.			
Document all findings and corrective actions.			