

Date: \_\_\_\_\_ Location: \_\_\_\_\_

Person(s) Conducting the Survey: \_\_\_\_\_

\_\_\_\_\_

Condition		Recommendation/Additional Info
Are fire exit maps near all exit doors?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Is seating in good condition?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Is auxiliary lighting (battery backup) provided in the event of a power failure?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
If overhead (clamp-on style) lighting is used, is each light individually secured with a safety cable?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Are costumes stored properly?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Is good general housekeeping maintained in the auditorium?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Are power tools used for set production?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Do storage areas above stage have proper guardrails, toe boards and ladder access?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Is proper clearance maintained in front of the electrical panel? (a minimum of 36-inch "clear space")	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Is the stage surface free of tripping hazards?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Is the fire curtain descent path blocked from sealing to the stage floor?	Yes <input type="checkbox"/> No <input type="checkbox"/>	

Condition		Recommendation/Additional Info
Is the fire curtain vacuumed every year to removed excess dust?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Is the fire curtain treated with flame retardant chemicals? NFPA 701 Flame Test	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Is the stage rigging inspected on a regular basis?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Is the orchestra pit covered with a pit net?	Yes <input type="checkbox"/> No <input type="checkbox"/>	